

Historical Leak Data

Contractor	Job #	Ref: #	Date	Time	Status	System Test	What Leaked	Manufacture
	2205	2300	09/12/09	11:22	Leak Final	Vent	Flex Connector Vent Box	Flex -Weld
	2205	2301	09/12/09	11:24	Leak Final	VR	VR Union	Steel Pipe - Single Wall
	2221	2245	10/25/09	15:44	Leak Pretest	Tk-3-DSL	Shear Valve	EBW
	2221	2266	10/26/09	13:55	Leak Pretest	Tk-3-DSL	Shear Valve	EBW
	2221	2278	10/26/09	16:06	Leak Pretest	Tk-3-DSL	Product 2nd Pipe	Smith Fibercast - Double Wall
	2221	2302	10/27/09	14:15	Leak Pretest		Product 2nd Fitting	Smith Fibercast - Double Wall
	2221	2325	10/28/09	8:00	Leak Final		Product Primary Fitting	Smith Fibercast - Double Wall
	2221	2358	10/28/09	13:25	Leak Pretest	Tk-1-87	Product Primary Pipe	Smith Fibercast - Double Wall
	2221	2359	10/28/09	13:45	Leak Pretest	Tk-1-87	Product Primary Pipe	Smith Fibercast - Double Wall
	2221	2404	11/01/09	13:35	Leak Pretest	Vent	Vent 2nd Pipe	Smith Fibercast - Double Wall
	2221	2408	11/01/09	15:30	Leak Pretest	Vent	VR 2nd Clamshell	Smith Fibercast - Double Wall
	2221	2409	11/01/09	15:35	Leak Pretest	Tk-2-91	Product 2nd Fitting	Smith Fibercast - Double Wall
	2221	2410	11/01/09	15:45	Leak Pretest	Tk-1-87	Product 2nd Pipe	Smith Fibercast - Double Wall
	2221	2245	10/25/09	15:44	Leak Pretest	Tk-3-DSL	Shear Valve	EBW
	2221	2266	10/26/09	13:55	Leak Pretest	Tk-3-DSL	Shear Valve	EBW
	2221	2278	10/26/09	16:06	Leak Pretest	Tk-3-DSL	Product 2nd Pipe	Smith Fibercast - Double Wall
	2221	2302	10/27/09	14:15	Leak Pretest	Tk-3-DSL	Product 2nd Fitting	Smith Fibercast - Double Wall
	2221	2325	10/28/09	8:00	Leak Final	Tk-1-87	Product Primary Fitting	Smith Fibercast - Double Wall
	2221	2358	10/28/09	13:25	Leak Pretest	Tk-1-87	Product Primary Pipe	Smith Fibercast - Double Wall
	2221	2359	10/28/09	13:45	Leak Pretest	Tk-1-87	Product Primary Pipe	Smith Fibercast - Double Wall
	2221	2404	11/01/09	13:35	Leak Pretest	Tk-2-91	Vent 2nd Pipe	Smith Fibercast - Double Wall
	2221	2408	11/01/09	15:30	Leak Pretest	Tk-2-91	VR 2nd Clamshell	Smith Fibercast - Double Wall
	2221	2409	11/01/09	15:35	Leak Pretest	Tk-2-91	Product 2nd Fitting	Smith Fibercast - Double Wall
	2221	2410	11/01/09	15:45	Leak Pretest	Tk-1-87	Product 2nd Pipe	Smith Fibercast - Double Wall
	2224	2231	11/02/09	9:48	Leak Final	Tk-3-DSL	ATG Crush Fitting	OPW
	2224	2245	11/02/09	11:41	Leak Final	Tk-3-DSL	ATG Riser Top	Veeder-Root
	2224	2246	11/02/09	11:56	Leak Final	Tk-2-91	Turbine LeakDetector	Veeder-Root
	2224	2250	11/02/09	12:30	Leak Final	Tk-1-87	Vent Extractor Tee	Steel Pipe - Single Wall
	2224	2231	11/02/09	9:48	Leak Final	Tk-3-DSL	ATG Crush Fitting	Veeder-Root
	2224	2245	11/02/09	11:41	Leak Final	Tk-3-DSL	ATG Riser Top	Steel Pipe - Single Wall
	2224	2246	11/02/09	11:56	Leak Final	Tk-2-91	Turbine LeakDetector	Veeder-Root
	2224	2250	11/02/09	12:30	Leak Final	Tk-1-87	Vent Extractor Tee	Steel Pipe - Single Wall